# Illinois Commerce Commission Pipeline Safety Pipeline Safety Report

Inspection #: 2016-P-00013

Operator: AMEREN ILLINOIS COMPANY	Operator ID#: 32513					
Exit Meeting Contact: Charles Tebbe	Total Man Days: 3					
Pipeline Safety Representative(s): Charles Gribbins						
Company Representative to Receive Report: Michael Fuller	Emailed Date:					
Company Representative's Email Address: mfuller2@ameren.com	02/09/2016					

#### **Inspection Summary**

Inspection Type	Location	ICC Analyst	Inspection Unit(s)	Man Day(s)	Inspection Date(s)	Contact(s)
Standard Inspection - Record Audit	Hillsboro	Charles Gribbins	Hillsboro/Mt. Clare		1/19/2016, 1/20/2016, 1/21/2016	Charles Tebbe

#### **Statement of Activities**

On January 19-21, 2016, Staff conducted a Record Audit at Ameren Illinois, in the Hillsboro/Mt Clare Service area, to determine compliance with applicable IL Adm. Codes and the Code of Federal Regulations adopted via IL Adm. Part 590. The audit included a review of company documents regarding the specific code sections as identified on the attached inspection form.

The records that were inspected were paper records and GCS records for the year 2014. The records that were inspected were for the months up to November, 2014. The records following that date are now being kept on a new computer system called MAXIMO. Some of the records inspected include pressure regulation, leak survey maps, buried pipeline examination, cathodic protection records, valve inspection records, patrolling records, and odorization records.

#### **Exit Statement**

# INSPECTION FINDINGS

# **Standard Inspection - Record Audit**

## Issues(s) Found:

[NO ISSUES FOUND]

#### Notice Of Amendment(s) Found:

[NO NOAS FOUND]

#### Notice Of Violation(s) Found:

[NO NOPVS FOUND]

### PAST INSPECTION FINDINGS

### Issue(s) Corrected:

[NO ISSUES CORRECTED]

# Illinois Commerce Commission Pipeline Safety Pipeline Safety Report

Inspection #: 2016-P-00013

Notice Of Amendment(s) Corrected:

[NO NOAS CORRECTED]

Notice of Violations(s) Corrected:

[NO NOPVS CORRECTED]